

TOWN OF WAPPINGER

FIRE INSPECTOR
Howard Prager - Ext. 127

Chelsea Fire District:
Yvonne Tompkins - Chair Person
James Tompkins

Hughsonville Fire District:
Bruce Flower
Robert Scott Bostwick

New Hackensack Fire District:
Roger Munoz
Chris Heady



FIRE PREVENTION BUREAU
20 MIDDLEBUSH ROAD
WAPPINGERS FALLS, NY 12590
PH: 845-297-1373
Fax: 845-297-0579
E-Mail: Hprager@townofwappinger.us

TOWN SUPERVISOR
Dr. Richard L. Thurston

TOWN BOARD
William H. Beale
Angela Bettina
Christopher Phillips
Michael Kuzmich



DATE:

Oct. 17, 2019

PROJECT NAME:

Tarpon Towers II, LLC Wireless Telecommunications Facility (Castle Point)

GRID #:

6056-C3-339420

ADDRESS:

110 Chelsea Rd, Wappingers Falls, NY

We have reviewed the above referenced project and submit the following comments to the Planning Board:

- ☐ NO COMMENTS, project meets our approval.
- ☐ Road names required. Submit name to Fire Inspector.
- ☒ The following items need to be addressed:

Recommend separate 911 addresses on property and private drive
Need to clear trees on fire access road

Will they allow an emergency response antenna on cell tower?

Date:

11/12/19

Signature:

Jm Longhin
Fire Prevention Bureau