

Fire Inspector:
Howard Prager - Ext. 127

TOWN OF WAPPINGER



Supervisor:
Richard Thurston

Chelsea Fire District:
Yvonne Tompkins - Chair Person
James Tompkins

Hughsonville Fire District:
Bruce Flower
Robert Scott Bostwick

New Hackensack Fire District:
Roger Munoz
Chris Heady

Town Board:
William H. Beale
Angela Bettina
Christopher Phillips
Al Casella

FIRE PREVENTION BUREAU

20 MIDDLEBUSH ROAD
WAPPINGERS FALLS, NY 12590
PH: 845-297-1373
Fax: 845-297-0579
hprager@townofwappingerny.gov



Date: 9-20-21
Project Name: Global Business Park Subdivision E
Location: Central Dutchess Industrial Center Site Plan
Grid No: Airport Drive
Address: 6259-04-908414
Airport Drive

We have reviewed the above referenced project and submit the following comments to the Planning Board:

- ☐ NO COMMENTS: Project meets with our approval.
- ☐ Road Names need to be submitted to the Fire Inspector for approval
- ☒ The following items need to be addressed:

Comments: 507 NYS Fire Code re: Hydrants are
required.

Need road name

Date: 10/12/21

Signature: Jm Tompkins

Fire Prevention Bureau Member