



**DUTCHESS COUNTY GOVERNMENT**  
**DEPARTMENT OF BEHAVIORAL & COMMUNITY HEALTH**

May 7, 2024

Bea Ogunti, Planning Secretary  
Town of Wappinger Planning Board  
20 Middlebush Road  
Wappingers Falls, NY 12590

Re: Panico Lot Line Re-alignment - SEQR  
Tax Map #135689-6157-04-575023, 557025  
Town of Wappinger

Dear Ms. Ogunti:

The following is in response to your submission to this office consisting of SEQR information for the above project.

1. This Department has no objection to the Town Planning Board serving as the lead agent for SEQR.
2. A survey map must be submitted to this Department by a New York State licensed land surveyor for review prior to receiving our "permission to file" stamp and signature on the map. It is preferred that this note be applied to the map prior to submission to this office such that no physical stamping is required. It is noted that the approval stamp currently shown on the map is for water supply and sewage disposal approval and must be removed from the survey map prior to receiving our "permission to file" stamp and signature.
3. It is noted that this map proposes an easement for the well serving lot 2. This office strongly recommends that the lot line be adjusted such that the well will be located on the parcel it is currently serving.

Should you find that we can be of assistance, please contact us at 486-3404.

Very truly yours,

A handwritten signature in blue ink, appearing to read "D. Keeler", is written over a horizontal line.

Daniel J. Keeler, P.E.  
Senior Public Health Engineer  
Environmental Health Services

cc: File 129424